

To ensure that tap water is safe to drink, the EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 800-426-4791.

Thank you for allowing us to continue providing your family with clean, quality water this year. In order to maintain a safe and dependable water supply, we sometimes need to make improvements that will benefit all our customers. These improvements are sometimes reflected as rate structure adjustments.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Center for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).



Please DO NOT FLUSH your unused/unwanted medications down toilets or sink drains.


More information is available at <http://www.dep.state.fl.us/waste/categories/medications/pages/disposal.htm>

We at the City of Groveland would like you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. If you have any questions or concerns about the information provided, please feel free to call any of the numbers listed.



2020 ANNUAL DRINKING WATER QUALITY REPORT

City of Groveland Water Department



We are pleased to present to you this year's, City of Groveland, **2020 Annual Drinking Water Report**. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is the Floridan Aquifer.

Our water is obtained from five (5) ground water wells and is chlorinated for disinfection purposes.

In 2020 the Florida Department of Environmental Protection performed a Source Water Assessment on our system. The assessment was conducted to provide information about any potential sources of contamination in the vicinity of our wells. There are 11 potential sources of contamination identified for this system with low to moderate susceptibility levels. The assessment results are available on the FDEP Source Water Assessment and Protection Program website at <https://fldep.dep.state.fl.us/swapp/>

This report shows our water quality results and what they mean.

*If you have any questions about this report or concerning your water utility, please contact **Craig Raines at 352-584-7228.***

We encourage our valued customers to be informed about their water utility. To ask questions or to learn more, please attend any of our regularly scheduled Council meetings. They are held on the first and third Monday of the month at 7:00 pm in the Puryear building, 243 S Lake Ave.

The City of Groveland routinely monitors for contaminants in your drinking water according to Federal and State laws, rules, and regulations. Except where indicated otherwise, this report is based on the results of our monitoring for the period of January 1 to December 31, 2020. Data obtained before January 1, 2020 and presented in this report is from the most recent testing done in accordance with the laws, rules, and regulations.

In the table below, you may find unfamiliar terms and abbreviations. To help you better understand these terms we have provided the following definitions:

- 💧 **Maximum Contaminant Level or MCL:** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- 💧 **Maximum Contaminant Level Goal or MCLG:** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

- **Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
- **Initial Distribution System Evaluation (IDSE):** An important part of the Stage 2 Disinfection By-Products Rule (DBPR). The IDSE is a one-time study conducted by water systems to identify distribution system locations with high concentrations of trihalomethanes (THMs) and haloacetic acids (HAAs). Water systems will use results from the IDSE, in conjunction with their Stage 1 DBPR compliance monitoring data, to select compliance monitoring locations for the Stage 2 DBPR.
- **Locational Running Annual Average (LRAA):** the average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.
- **Maximum residual disinfectant level or MRDL:** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum residual disinfectant level goal or MRDLG:** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **“ND” means not detected and indicates that the substance was not found by laboratory analysis.**
- **Parts per billion (ppb) or Micrograms per liter (µg/l):** one part by weight of analyte to 1 billion parts by weight of the water sample.
- **Parts per million (ppm) or Milligrams per liter (mg/l):** one part by weight of analyte to 1 million parts by weight of the water sample.
- **Picocurie per liter (pCi/L):** measure of the radioactivity in water.

Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. The City of Groveland is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking.

If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 2020 we did not monitor for asbestos and therefore cannot be sure of the quality of our drinking water during that time.



WHAT HAPPENED?

We are required to collect asbestos samples every 9 years. This sample was due by December 31, 2020; however, we did not collect the samples until February 9, 2021.

WHAT WE ARE DOING:

We have since received the results of the sample and asbestos was **undetected**.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- ⊗ Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- ⊗ Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- ⊗ Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- ⊗ Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- ⊗ Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

NON-SECONDARY CONTAMINANTS TABLE

RADIOACTIVE CONTAMINANTS							
Contaminant and Unit of Measurement	Dates of sampling (mo/yr)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Alpha emitters (pCi/L)	12/17	N	5.3	1.4 - 5.3	0	15	Erosion of natural deposits
Radium 226 + 228 or combined radium (pCi/L)	12/17	N	2.3	1.7 - 2.3	0	5	Erosion of natural deposits
INORGANIC CONTAMINANTS							
Contaminant and Unit of Measurement	Dates of sampling (mo/yr)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Barium (ppm)	05/20	N	0.0103	0.0087 - 0.0103	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Sodium (ppm)	05/20	N	13.20	4.24 - 13.20	N/A	160	Saltwater intrusion, leaching from soil
VOLATILE ORGANIC CONTAMINANTS							
Contaminant and Unit of Measurement	Dates of sampling (mo/yr)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Xylenes (ppm)	05/20 08/20 11/20	N	1.54	ND - 1.54	10	10	Discharge from petroleum factories; discharge from chemical factories
STAGE 1 DISINFECTANTS AND DISINFECTION BY-PRODUCTS							
For bromate, chloramines, or chlorine, the level detected is the highest running annual average (RAA), computed quarterly, of monthly averages of all samples collected. The range of results is the range of results of all the individual samples collected during the past year.							
Disinfectant or Contaminant and Unit of Measurement	Dates of sampling (mo/yr)	MCL or MRDL Violation Y/N	Level Detected	Range of Results	MCLG or MRDLG	MCL or MRDL	Likely Source of Contamination
Chlorine (ppm)	01/01/20 - 12/31/20	N	1.52	0.8 - 2.1	MRDLG = 4	MRDL = 4.0	Water additive used to control microbes
STAGE 2 DISINFECTANTS AND DISINFECTION BY-PRODUCTS							
Contaminant and Unit of Measurement	Dates of sampling (mo/yr)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Haloacetic Acids (HAA5) (ppb)	02/20	N	14.6	13.8 - 14.6	N/A	60	By-product of drinking water disinfection
Total Trihalomethanes (TTHM) (ppb)	02/20	N	27.1	26.3 - 27.1	N/A	80	By-product of drinking water disinfection
LEAD AND COPPER							
Contaminant and Unit of Measurement	Dates of sampling (mo/yr)	AL Exceeded (Y/N)	90 th Percentile Result	No. of sampling sites exceeding the AL	MCLG	AL (Action Level)	Likely Source of Contamination
Copper (tap water) (ppm)	08/20 - 09/20	N	0.801	0	N/A	60	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (tap water) (ppb)	08/20 - 09/20	N	2.2	0	N/A	80	Corrosion of household plumbing systems; erosion of natural deposits